

CITY OF MITCHELL

City Council Meeting
Agenda Item Request



The deadline for agenda items is Wednesday at noon, prior to the City Council Meeting

Meeting Date Requested: Requested By:

Desired Action of City Council: Authorization Approval Resolution
 Ordinance Citizen Request Discussion

Amount Budgeted in current fiscal year for this item (if applicable):

Agenda Item:

Explanation/Background of Agenda Item Requested:

Agreement 2021-52 with Hydro Klean, LLC will line a sanitary sewer main which is exposed to the Dry Run Creek. The line is a 24" VCP truck line that is located just to the east of Burr Street and Iverson's car lot. The line crosses the creek and is exposed. The line does not appear to have any damage but could contribute to sanitary sewer flow in the creek if compromised. Hydro Klean has provided a cost to line the sewer main with a 24" PVC liner and provide by-pass pumping to complete the work. Old VCP or clay sewer main is typically brittle and can break easily. Installing the PVC liner will provide additional protection and seal the VCP joints. The total cost is estimated to be \$103,112.00.

Staff recommends City Council approval of the attached agreement with Hydro Klean, LLC for an estimated amount of \$103,112.00.